

CENTRAL FIRE STATION BUILDING ADDITION BID NO. 2825

ADDENDUM #1

1. No Geotechnical report is required.
2. The building pad is already in place.
The existing ground is high enough where there will be no fill required.
3. Existing elevation at building pad area is 61.76.
4. The roof is to be Standing seam galvalume finish.
5. The only insulation will be the noted sprayed on polyurethane on the roof.
6. All doors are steel material on steel frames.
7. End wall A – these are steel overhead sectional, manual operating doors.
8. All panels will be a standard sand color.
9. All electrical and plumbing will be done by others.

Armando Gutierrez, Jr.
5-9-2008

