



P. O. BOX 1458 - KINGSVILLE, TEXAS 78364

Addendum No. 2

**CDBG-MIT GLO CONTRACT NO. 22-082-016-D218
(CITY OF KINGSVILLE BID NO. 24-04)**

**CITY OF KINGSVILLE GLO SS PROJECT 5 (E. LOTT AVE.) SANITARY SEWER IMPROVEMENTS
&
CITY OF KINGSVILLE GLO SS PROJECT 6 (10TH STREET) SANITARY SEWER IMPROVEMENTS**

The above referenced Bid Opening is modified to provide additional information as follows:

- I. **GLO SS Project 5 (E. Lott Ave.) Sanitary Sewer Improvements** – Revised/Added items as follows:
 - a. Revised Invitation for Bids to include MH-3 replacement in Base Bid in lieu of “CIP Manhole Liner” on Additive Alternate Bid No. 1.
 - b. Additive Alternate Bid No. 2 to include demolition and point repairs to storm sewer line adjacent to wastewater MH-3.
 - c. Added Manhole specifications and details.
 - d. Revised Engineer’s Estimate.
 - e. Revised project time will be 120 calendar days in lieu of 90 calendar days.

- II. **GLO SS Project 6 (10th Street) Sanitary Sewer Improvements** – Revised item as follows:
 - a. Revised construction plans for removal of “Jeffcoat 326” from Additive Alternate Bid No. 1, Item B1 (Existing Manhole Protective Coating (60 MIL), Jeffcoat 326).

- III. **GLO SS Project 5 (E. Lott Ave.) Sanitary Sewer Improvements and GLO SS Project 6 (10th Street) Sanitary Sewer Improvements** – Clarification and substitution is as follows:
 - a. *Specification 027207B (Rehabilitation of Manholes and Wet Wells with CIP Liner)* allows for alternative products to be used, contingent on approval from Engineer.
 - b. *Specification 027200 (Control of Wastewater Flows)*. The contractor is responsible for constructing a sanitary sewer bypass system that will prevent spills and overflows. The contractor will be responsible for any spills and overflows. Lay-flat hoses are acceptable for use in bypass pumping operations.
 - c. *Specification 027614 (Cured-in-Place-Pipe (CIPP) for Rehabilitation of Gravity Wastewater Line)*, the use of air as an inversion method and water steam as a curing method is acceptable.
 - d. SewperCoat PG is an acceptable product for manhole rehabilitation.

- IV. No partial bids shall be submitted for Base Bids or Additive Alternate Bids, respectively. All bidders must submit a unit cost and total with each bid item.



P. O. BOX 1458 - KINGSVILLE, TEXAS 78364

A signed copy of this Addendum No. 2 must accompany each proposal submission. In doing so, the Proposer acknowledges receipt of Addendum No. 2, and agrees if selected as the successful Proposer, to be bound by the terms as amended. All terms of Bid No. 24-04 which are not amended hereby remain in full force and effect.

Questions concerning this Addendum No. 2 should be addressed to City Engineer, Rutilio P. Mora, Jr., P.E. via email to rmora@cityofkingsville.com.

Rutilio P. Mora Jr.
Rutilio P. Mora Jr. P.E., City Engineer

January 26, 2024
Date